



REVISION HISTORY				
REV	DESCRIPTION	DESIGNER	DATE	CHECKED BY
1	FRP RISER HEIGHT CHANGED	M.M.	1/12/2017	


Site Level Confirmation	
Finished Surface Level (FSL)	RL:
Access Cover Thickness	mm
Inlet Invert Level	RL:
Outlet Invert Level	RL:
Company:	
Name:	
Date:	




**PLAN VIEW**



**ELEVATION VIEW**



**SIDE VIEW  
OUTLET**



**ISOMETRIC VIEW**

APPROVED.....	<input type="checkbox"/>
NAME.....	
SIGNED.....	
DATE...../...../.....	

**ISSUED FOR CONSTRUCTION**

**NOTICE:**  
SYSTEM PIPEWORK MUST HAVE AT LEAST 250 MM OF FALL TO OPERATE CORRECTLY.

TOLERANCE: ALL DIMENSIONS 10mm UNLESS OTHERWISE STATED.

CLIENT:

DISTRIBUTOR :

CONFIDENTIAL - The drawings must not be disclosed to any third parties without written permission from SPEL Environmental Sydney. Unauthorised disclosure may result in prosecution.  
© SPEL Environmental - This drawing is the property of SPEL Environmental ABN: 83 151 832 629 and is subject to return on demand. It is submitted for the use only in connection with the proposal and contracts of SPEL Environmental with the expressed conditions that it is not to be reproduced or copied in any form. This data must only be used in accordance with our standard terms and conditions.  
© Copyright  
SPEL Environmental accepts no responsibility for any loss or damage resulting from any person acting on this information. The details and dimensions contained in this document may change, please check with SPEL Environmental for confirmation of current specifications.

Drawn	Date
M.M.	1/12/2017
Check	Date
Verified	Date
Approved	Date
Request No.	
RN4876	

100 Silverwater Road Silverwater NSW 2128  
PH: 1300 773 500 | E: sales@spel.com.au  
www.spel.com.au

PROJECT :			
TITLE SPEL HYDROSYSTEM 1500 SHS.150D-1500C-03.225.PVC.SP FRP TANK 1500 DIA.- 3 FILTER CARTRIDGES			
SCALE	N.T.S	SIZE	A3
SHEET	1	REV	1
CUSTOMER CODE :	DWG No. SP17-HY41900-P		

D:\Vault\Working Folder\Designs\SPEL\PRODUCTS\HYDROSYSTEM\1500 SERIES\PROJECT\17 PENNANT ST, PARARAMATT\SP17-HY41900-P.dwg