REVISION HISTORY				
REV	DESCRIPTION	DESIGNER	DATE	CHECKED BY
1	INITIAL DESIGN	M.MAKIN	29/10/2019	M.M.

Site Level Confirmation	
Finished Surface Level (FSL)	RL:
Access Cover Thickness	mm
Inlet Invert Level	RL:
Outlet Invert Level	RL:
Company:	
Name:	
Date:	

PLAN VIEW

ISOMETRIC VIEW

ELEVATION VIEW

SIDE VIEW
OUTLET

NOTICE:
SYSTEM PIPEWORK MUST HAVE AT LEAST
250 MM OF FALL TO OPERATE CORRECTLY.

TOLERANCE: ALL DIMENSIONS 10mm UNLESS OTHERWISE STATED.

CLIENT:

DISTRIBUTOR :

CONFIDENTIAL - The drawings must not be disclosed to any third parties without written permission from SPEL Environmental Sydney. Unauthorised disclosure may result in prosecution.
© SPEL Environmental - This drawing is the property of SPEL Environmental ABN: 83 151 832 629 and is subject to return on demand. It is submitted for the use only in connection with the proposal and contracts of SPEL Environmental with the expressed conditions that it is not to be reproduced or copied in any form. This data must only be used in accordance with our standard terms and conditions.
© Copyright
SPEL Environmental accepts no responsibility for any loss or damage resulting from any person acting on this information.
The details and dimensions contained in this document may change, please check with SPEL Environmental for confirmation of current specifications.

Drawn	M.MAKIN	Date 29/10/2019
Check	M.M.	Date 2/05/2016
Verified		Date
Approved		Date
Request No.	RN1661	

spelstormwater
joy in water
spel.com.au

PROJECT :

TITLE
SPEL HYDROSYSTEM 3500
SHS.400D-1500C-39.375.PVC
FRP TANK 4000 DIA.- 39 FILTER CARTRIDGES
GENERAL ARRANGEMENT

SCALE	SIZE	SHEET	REV
N.T.S	A3	1	1

CUSTOMER CODE :
DWG No. SP19-HY21290-P

E:\Vault Working Folder\Designs\SPEL\PRODUCTS\HYDROSYSTEM\4000 SERIES\STANDARD\SHS.400D-1500C-39.375.PVC\SP19-HY21290-P.idw