


REVISION HISTORY				
REV	DESCRIPTION	DESIGNER	CREATION DATE	CHECKED BY
1	INITIAL RELEASE	M.MAKIN	3/10/2017	

D


C

B

A




PLAN VIEW




ELEVATION VIEW

Site Level Confirmation	
Finished Surface Level (FSL)	RL:
Access Cover Thickness	mm
Inlet Invert Level	RL:
Outlet Invert Level	RL:
Company:	
Name:	
Date:	




SIDE VIEW

FRP TANK
I.D. 2200 x 2500H



ISOMETRIC VIEW

NOTICE:
SYSTEM PIPEWORK MUST HAVE AT LEAST
250 MM OF FALL TO OPERATE CORRECTLY.

TOLERANCE: ALL DIMENSIONS 10mm UNLESS OTHERWISE STATED.											
CLIENT:		DISTRIBUTOR :		CONFIDENTIAL - The drawings must not be disclosed to any third parties without written permission from SPEL Environmental Sydney. Unauthorised disclosure may result in prosecution. © SPEL Environmental - This drawing is the property of SPEL Environmental ABN: 83 151 832 629 and is subject to return on demand. It is submitted for the use only in connection with the proposal and contracts of SPEL Environmental with the expressed conditions that it is not to be reproduced or copied in any form. This data must only be used in accordance with our standard terms and conditions. © Copyright SPEL Environmental accepts no responsibility for any loss or damage resulting from any person acting on this information. The details and dimensions contained in this document may change, please check with SPEL Environmental for confirmation of current specifications.		<div>Drawn M.MAKIN</div> <div>Check</div> <div>Verified</div> <div>Approved</div> <div>Request No. RN4612</div>		<div></div> <div>spelstormwater</div> <div>joy in water</div> <div>spel.com.au</div>		<div>PROJECT :</div> <div>TITLE SPEL HYDROSYSTEM 2200 SHS.220D-1500C-09.375.PVC FRP TANK 2200 DIA.- 09 FILTER CARTRIDGES</div> <div>SCALE N.T.S</div> <div>SIZE A3</div> <div>SHEET 1</div> <div>REV 1</div> <div>CUSTOMER CODE :</div> <div>DWG No. SP17-HY38900-S</div>	

E:\Vault Working Folder\Designs\SPEL\PRODUCTS\HYDROSYSTEM\2200 SERIES - FRP\STANDARD\SHS.220D-1500C-09.375.PVC\SP17-HY38900-S.dwg