


Site Level Confirmation	
Finished Surface Level (FSL)	RL:
Access Cover Thickness	mm
Inlet Invert Level	RL:
Outlet Invert Level	RL:
Company:	
Name:	
Date:	



ISOMETRIC VIEW

NOTICE:
SYSTEM PIPEWORK MUST HAVE AT LEAST
250 MM OF FALL TO OPERATE CORRECTLY.

TOLERANCE: All Dimensions to Closest 10 mm & +/- 30 mm

ALL INTERCONNECTING PIPEWORK, PITS AND ASSOCIATED DRAINAGE BY OTHERS

CLIENT:

CONFIDENTIAL - The drawings must not be disclosed to any third parties without written permission from SPEL STORMWATER. Unauthorised disclosure may result in prosecution.
© SPEL STORMWATER - This drawing is the property of SPEL STORMWATER ABN: 83 151 832 629 and is subject to return on demand. It is submitted for the use only in connection with the proposal and contracts of SPEL STORMWATER with the expressed conditions that it is not to be reproduced or copied in any form. This data must only be used in accordance with our standard terms and conditions.
© Copyright
SPEL STORMWATER accepts no responsibility for any loss or damage resulting from any person acting on this information. The details and dimensions contained in this document may change, please check with SPEL STORMWATER for confirmation of current specifications.

Drawn	Date
J.MAKIN	10/02/2021
Check	Date
Verified	Date
Approved	Date
Request No.	
RN2981	



PROJECT :

TITLE
SPEL HYDROSYSTEM 2500
SHS.250D-1500C-16.375.
FRP TANK 2500 DIA.- 16 FILTER CARTRIDGES

SCALE	SIZE	SHEET	REV
N.T.S	A3	1	1
CUSTOMER CODE :		DWG No.	
		SP21-HY12160-P	

1	INITIAL RELEASE	J.MAKIN	10/02/2021	
REV	DESCRIPTION	DESIGNER	CREATION DATE	CHECKED BY